



**Savings PER FIXTURE: 2 Lamp T-5 Fixture versus 250 Watt HID Fixture**

**Energy Savings Per Fixture**

<b>KWh Rate</b>	<b>12 hrs / 6 days 3744 Annual Hours</b>	<b>18hrs / 6 days 5616 Annual Hours</b>	<b>24 hrs / 6 days 7488 Annual Hours</b>	<b>12hrs / 7 days 4368 Annual Hours</b>	<b>18hrs / 7 days 6552 Annual Hours</b>	<b>24hrs / 7 days 8760 Annual Hours</b>
\$0.07	\$47.70	\$71.55	\$95.40	\$55.65	\$83.47	\$111.60
\$0.08	\$54.51	\$81.77	\$109.03	\$63.60	\$95.40	\$127.55
\$0.09	\$61.33	\$91.99	\$122.65	\$71.55	\$107.32	\$143.49
\$0.10	\$68.14	\$102.21	\$136.28	\$79.50	\$119.25	\$159.43
\$0.11	\$74.95	\$112.43	\$149.91	\$87.45	\$131.17	\$175.38
\$0.12	\$81.77	\$122.65	\$163.54	\$95.40	\$143.10	\$191.32
\$0.13	\$88.58	\$132.87	\$177.17	\$103.35	\$155.02	\$207.26
\$0.14	\$95.40	\$143.10	\$190.79	\$111.30	\$166.94	\$223.20
\$0.15	\$102.21	\$153.32	\$204.42	\$119.25	\$178.87	\$239.15

\*Determine hours of Operation and KWh rate: find the per fixture annual savings and multiply that per fixture savings X the number of fixtures in the facility